



Entwicklungs- und Prüflabor  
Holztechnologie GmbH  
Zellescher Weg 24 · D-01217 Dresden  
www.eph-dresden.de



Deutsche  
Akkreditierungsstelle  
D-PL-11054-01-00

Deutsches  
Institut  
für  
Bautechnik

DIBt

Recognized body of DIBt  
and European Notified Body  
for construction products (Number: 0766)

Test laboratory accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)  
(German Accreditation System of Testing) acc. to DIN EN ISO/IEC 17025

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-13-08-19-01

**Product:** Laminate floor covering with the structures BS, BF, WG, RF, EX, OA, WO, PS, WF, SP, AS, SU, GL, LP, EW, RS, DB, NL, VH, VO, HC, RC

**Producer:** Kronoflooring GmbH  
Mühlbacher Str. 1  
01561 Lampertswalde / Dresden

**Order:** Determination of the slippery resistance according to EN 13893 / classification according to EN 14041

**Test reports:** 265188  
276279  
279047  
270181  
271193  
271355  
272008  
272495

**Result:** The tested laminate floor covering structures are fulfilling with the values of  $\mu = 0.41 - 0.70$  the requirements of the class DS ( $\mu \geq 0.30$ ) according to EN 14041 (CE-labelling).

Dresden, 19 August 2013

Head of laboratory



Engineer in charge